

TANK DESIGN WORKSHEET

DESIGN CRITERIA

Location	Tank maintain temp. (Tm)	Minimum ambient temperature (Ta)	Delta temp. (ΔT = Tm – Ta)	Start-up temperature	Process operating temperature	System limit temperature	Max. intermittent exposure temp.
indoors							
outdoors							
Example Outdoors	80°F	-20°F	100°F	0°F	200°F	500°F	200°F
Insulation type and thickness		Tank wall material	Tank wall thickness	Fluid in tank	Area classification	Area T-rating	Chemical exposure
		metal			nonhazardous		none
		plastic			hazardous CID2		mild inorganics
					hazardous CID1		organics/corrosives
Example Cal sil 1.5"		Metal	0.25"	Heavy oil	Hazardous CID2	T2 (300°C)	Organics/corrosives

CALCULATION OF TANK HEAT LOSS

nVent provides a wide selection of heat-tracing solutions for tanks and vessels. For detailed information about tank heating products, refer to the Tank Heating design guide (H56887).

$$Q_T = Q_V + Q_S + Q_A$$

Where:

Q_T = Total heat loss of the tank

Q_V = Heat loss through the insulated body of the tank

Q_S = Heat loss through the tank support mechanism (slab, legs, saddle, or other base support)

Q_A = Heat loss through accessories such as manholes, handholds, ladders, or handrails

Calculation of Q_V , heat loss through insulated tank body:

Geometry of tank Formula for surface area

Cylindrical $\pi \times D \times h$ plus ends

Truncated cone $\pi \times (D + d) \times S/2$ plus ends

Tank Design Worksheet

Calculation of surface area

$$(A_{\text{body}}) = \pi DH$$

Add ends if required

$$(A_{\text{end}}) = \pi D^2/4 \text{ or}$$

$$(A_{\text{end}}) = (\pi D^2/4) \times 2$$

Total insulated surface area (ft²)

$$A_v (A_v = A_{\text{body}} + A_{\text{ends}}) \text{ (ft}^2\text{)}$$

Note: If different areas of the tank surface have different types of insulation or different thicknesses of insulation, a different (qv) heat loss rate and (f) insulation adjustment factor should be calculated for each area and the total heat losses should be added. Q_v is the total heat loss through the insulated portions of the tank wall.

$$Q_v = A_v \times q_v \times f =$$

Calculate Q_s, the heat loss through the base support of the tank:

Type of support (Concrete slab or earth foundation, legs, concrete saddles or uninsulated skirt)

Calculation of support heat loss

$$Q_s = \text{Heat Loss of the base support} \times \text{the quantity of base supports (as provided in H56887).} \quad (\text{watts})$$

The next step is to calculate Q_A, the heat loss through the accessories (manholes, handholds, ladders, handrails) of the tank. See Tank Heating design guide (H56887), and calculate Q_A, the heat loss through the accessories:

Type of accessory

$$\text{Calculation of accessory heat loss} \quad (\text{watts})$$

$$Q_A = (\text{Heat loss variable is provided in H56887}). \quad (\text{watts})$$

Calculation of total heat loss

$$Q_T = Q_v + Q_s + Q_A \quad (\text{watts}) \text{ Outdoor application}$$

$$Q_T = 0.9 \times (Q_v + Q_s + Q_A) \quad (\text{watts}) \text{ Indoor application}$$

nVent recommends a 20% safety factor for tank heat loss design.

Final design heat loss

$$Q_F = Q_T \times 1.20 \quad (\text{watts})$$

Tank Design Worksheet

PRODUCT SELECTION

Tank heating applications can be quite varied. For this reason, nVent offers a range of technologies to optimize your tank and vessel heat-tracing system.

Numerous nVent products can be used to maintain temperatures of tanks. See Tank Heating design guide (H56887) for information on product selection. Pay particular attention to the maximum exposure temperature and the system limit temperature. The maximum exposure temperature is the highest temperature to which the heating cable will be exposed. Heating cables can be damaged by temperatures in excess of those the cables are designed to handle. The system limit temperature is the highest temperature to which the heating cables may expose the system. The tank or tank contents could be damaged by excessively high temperatures.

Once suitable products are selected based on temperatures, the decision is often based on economics. It is important to consider both product cost and the labor required to install the products.

Pad heater	Q_p (Watts/unit)
Pads required = Q_F / Q_p	
Heating cable	$P_{\text{heating cable}}$ (watts/ft) at T_m (maintain temperature)

Note: See Section 6 to determine if P_{adj} should be used in place of $P_{\text{heating cable}}$

$$P_{adj} = f_{adj} \times P_{\text{heating cable}}$$

$$\text{Feet of heating cable required} = Q_F / P_{adj} \text{ (or } P_{\text{heating cable}} \text{ if } f_{adj} = 1.0)$$

See the Tank Heating design guide (H56887) for information on installing the heating cable on the tank. If aluminum tape is used for self-regulating heating cable installation, or if the heating cable is to be installed on a plastic tank, be sure to use the above formula to account for the change in power output of the self-regulating heating cable. Values for f_{adj} can be found in the Tank Heating design guide (H56887), Table 2. Also see the Tank Heating design guide (H56887), Table 3 for the circuit length adjustment factors for self-regulating heating cables.

North America

Tel +1.800.545.6258
Fax +1.800.527.5703
thermal.info@nvent.com

Europe, Middle East, Africa

Tel +32.16.213.511
Fax +32.16.213.604
thermal.info@nvent.com

Asia Pacific

Tel +86.21.2412.1688
Fax +86.21.5426.3167
cn.info@nvent.com

Latin America

Tel +1.713.868.4800
Fax +1.713.868.2333
thermal.info@nvent.com



nVent.com

Our powerful portfolio of brands:

CADDY ERICO HOFFMAN RAYCHEM SCHROFF TRACER